

# **Annual Drinking Water Quality Report Lakota, North Dakota 2019**

We're pleased to present to you this year's *Annual Drinking Water Quality Report*. This report is designed to inform you about the safe clean water we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. The City of Lakota utilizes the McVille Aquifer for municipal water.

Our public water system, in cooperation with the North Dakota Department of Health, has completed the delineation and contaminant/land use inventory elements of the North Dakota Source Water Protection Program. Based on the information from these elements, the North Dakota Department of Health has determined that our source water is “*not likely susceptible*” to potential contaminants.

The City of Lakota is pleased to report that our drinking water is safe and meets federal and state requirements. This report shows our water quality and what it means.

If you have any questions about this report or concerning your water utility, please contact Amie Vasichek, City Auditor @ (701) 247-2454. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Monday of each month at 6:00 PM in Lakota City Hall. If you are aware of non-English speaking individuals who need help with the appropriate language translation, please call Amie at the number listed above.

Lakota would appreciate it if large volume water customers would please post copies of the *Annual Drinking Water Quality Report* in conspicuous locations or distribute them to tenants, residents, patients, students, and/or employees, so individuals who consume the water, but do not receive a water bill, can learn about our water system.

Lakota routinely monitors for contaminants in your drinking water according to Federal and State laws. The following table shows the results of our monitoring for the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2019. As authorized and approved by EPA, the state has reduced monitoring requirements for certain contaminants to less often than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of our data [e.g., for inorganic contaminants], though representative, is more than one-year-old.

The sources of drinking water (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land, or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

**Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.

**Inorganic contaminants**, such as salts and metals, which can be naturally occurring or result from urban storm water, industrial or domestic wastewater discharges, oil production, mining or farming.

**Pesticides and herbicides**, which come from a variety of sources such as agriculture, urban storm water runoff and residential uses.

**Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can, also, come from gas stations, urban storm water runoff and septic systems.

**Radioactive contaminants**, which can be naturally occurring or be the result of oil and gas production and mining activities.

To ensure that tap water is safe to drink, the Environmental Protection Agency (EPA) prescribes regulations which limit the number of certain contaminants in water provided by public water systems.

The Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

In the following table, you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

**Not applicable (NA), No Detect (ND)**

**Parts per million (ppm) or Milligrams per liter (mg/l)** - one part per million corresponds to one minute in two years or a single penny in \$10,000.

**Parts per billion (ppb) or Micrograms per liter (µg/l)** - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

**Picocuries per liter (pCi/l)** –Pico curies per liter is a measure of the radioactivity in water.

**Action Level (AL)** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Treatment Technique (TT)** - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

**Maximum Contaminant Level** - The “Maximum Allowed” (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal** - The “Goal” (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL)** – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)** – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

<b>2019 TEST RESULTS FOR THE CITY OF LAKOTA, NORTH DAKOTA</b>								
<u>Contaminant</u>	<u>MCLG</u>	<u>MCL</u>	<u>Highest Compliance Level</u>	<u>Unit Measurement</u>	<u>Range Of Detections</u>	<u>Date (year)</u>	<u>Violation Yes/No Other Info</u>	<u>Likely Source of Contamination</u>
<b>Lead/Copper</b>								
Copper	1.3	AL=1.3 90% Value	0.174	ppm	N/A	2019	0 Sites exceeded AL	Corrosion of household plumbing systems, erosion of natural deposits; leaching from wood preservatives
Lead	15	AL=15 90% Value	6.44	ppb	N/A	2019	1 Site exceeded AL	Corrosion of household plumbing systems, erosion of natural deposits
<b>Inorganic Contaminants</b>								
Arsenic	10	0	**7.83	ppb	N/A	2016	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Barium	2	2	0.0405	ppm	N/A	2017	No	Discharge of drilling wastes, Discharge from metal refineries, Erosion of natural deposits
Fluoride	4	4	0.652	ppm	N/A	2017	No	Erosion of natural deposits, Water additive which promotes strong teeth, Discharge from fertilizer and aluminum factories
Nitrate-Nitrite	10	10	0.2	ppm	N/A	2019	No	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
<b>Radioactive Contaminants</b>								
Gross Alpha, Including RA, Excluding RN & U	15	15	3.79	pCi/l	N/A	2017	No	Erosion of natural deposits
Radium, Combined (226, 228)	5	N/A	0.39	pCi/l	N/A	2017	No	Erosion of natural deposits
Uranium, Combined	30	N/A	1.62	ppb	N/A	2017	No	Erosion of natural deposits
<b>Disinfectants</b>								
Chlorine	MRDL=4	MDRL=4	0.9	ppm	0.1 to 1.68	2019	No	Water additive used to control microbes
<b>Unregulated Contaminants</b>								
Manganese	N/A	N/A	0.03	ppm	N/A	2017	No	N/A
<b>Stage 2 Disinfection Byproducts (System-Wide)</b>								
HAA5	N/A	60	1	ppb	N/A	2019	No	By-product of drinking water chlorination
TTHM	N/A	80	20	ppb	N/A	2019	No	By-product of drinking water chlorination

\*If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Lakota is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. **Use water from the cold tap for drinking and cooking. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking.** If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

\*\*While your drinking water meets EPA's standard for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic which is mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure.

Your water system monitors for several unregulated organic contaminants, which could indicate a contamination of the water supply from a pesticide or petroleum spill or leak. Your water system also monitors for sulfate, which at the present time is an unregulated contaminant.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (1-800-426-4791).

MCL's are set at very stringent levels. To understand the possible health effects described for many regulated contaminants, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

Infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested and flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the Safe Drinking Water Hotline (1-800-426-4791).

**Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons, such as, persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control and Prevention (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).**

Tampering with a public water facility is a federal offense. Please report any suspicious activity to local law enforcement.

Please call Amie Vasichek, City Auditor @ (701) 247-2454 if you have questions concerning your city's water system.

The City of Lakota works diligently to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life, and our children's future.

